



Scottish & Southern Electricity Networks

Appendix G Part 5

Summary Table (SEPD)

Please note that the information provided here is correct as of the date and time uploaded. Responses are updated on a monthly basis and are intended to be indicative only.

GSP	Part 1 (MW)	Part 2 (MW)	Part 3 (MW)	Part 4 (MW)	Current Material Headroom (MW)	New connections subject to Statement of Works	Aggregated Developer Capacity (MW)	Subject to site specific requirements	Subject to Active Network Management (SWANs)
AXMINSTER	60.78	0	93	0	0.13	YES	153.91	YES	YES
BRAMLEY	87.595	140.089	0	0	137.416	NO	365.1	YES	NO
BOTLEY WOOD	65.8	0	26.25	0	34.25	YES	126.3	YES	YES
CHICKERELL	69.43	0	23.5	0	62.8	NO	155.73	YES	YES
COWLEY	371.128	111.19	0	0	75.742	YES	558.06	YES	NO
FAWLEY	602.94	0	0	0	120.9	NO	723.84	YES	YES
FLEET	255.44	0	203.2	0	90.1	YES	548.74	YES	YES
LOVEDEAN	288.67	0	104.8	0	112.63	NO	506.1	YES	YES
MANNINGTON	337.384	0	249.22	0	87.476	NO	674.08	YES	YES
MELKSHAM	366.645	183.69	0	0	54.835	YES	605.17	YES	NO
MINETY	298.5	295.46	0	0	14.37	YES	608.33	YES	NO
NURSLING	158.03	0	103.5	0	169.37	YES	430.9	YES	YES



Scottish & Southern
Electricity Networks